


NOTE:

1. STAINLESS STEEL FIRE RISER TO BE COMPOSED OF A SINGLE EXTENDED 90° FITTING OF FABRICATED 304 OR 316 STAINLESS STEEL TUBING WITH WORKING PRESSURE OF 175 PSI, BY AMES FIRE AND WATERWORKS OR APPROVED EQUAL.

	TRAVIS COUNTY WATER CONTROL AND IMPROVEMENT DISTRICT No. 17 STANDARD DETAILS	FIRE RISER	
	ADOPTED: 02/24/2017	THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR APPROPRIATE USE OF THIS STANDARD.	DETAIL NO. W12